

表三四三～一 非金屬導線管管徑之選定

導線線徑		絕 緣 導 線 數								
單線 (mm)	絞線 (mm ²)	1	2	3	4	5	6	7	8	9
		導線管最小管徑 (mm)								
1.6		16	16	16	16	16	20	20	28	28
2.0	3.5	16	16	16	16	20	20	28	28	28
2.6	5.5	16	16	16	20	28	28	28	35	35
	8	16	20	20	28	28	35	35	35	41
	14	16	20	28	28	35	35	41	41	41
	22	16	28	35	35	41	41	52	52	52
	30	16	35	35	41	41	52	52	52	65
	38	20	35	41	41	52	52	52	65	65
	50	20	41	41	52	52	65	65	65	80
	60	20	41	52	52	65	65	65	80	80
	80	28	52	52	65	65	65	80	80	80
	100	28	52	65	65	80	80	80	80	100
	125	35	65	65	65	80	80	100	100	100
	150	35	65	65	80	80	100	100	100	100
	200	41	65	80	80	100	100	100		
	250	41	80	80	100	100	100			
	325	52	80	100	100					
	400	52	100	100						
	500	65	100	100						

註：1. 管徑根據 CNS 規定以標稱管徑表示。
 2. 管徑超過 100 mm 者，其導線數依表三二八～八規定計算。